



# California Regional Water Quality Control Board

## San Diego Region



Linda S. Adams  
Acting Secretary for  
Environmental Protection

Over 50 Years Serving San Diego, Orange, and Riverside Counties  
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

Edmund G. Brown, Jr.  
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353  
(858) 467-2952 • Fax (858) 571-6972  
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

March 4, 2011

In reply refer to:  
**638334:rsunjed**

Mr. A.C. Entingh  
Head, Environmental Compliance Department  
AC/S Environmental Security  
U.S. Marine Corps Base  
P.O. Box 555008  
Camp Pendleton, CA 92055-5008

Dear Mr. Entingh:

**SUBJECT: REVIEW OF MONITORING REPORTS FOR USMC SOUTHERN  
REGION TERTIARY TREATMENT PLANT (SRTTP)**

The California Regional Water Quality Control Board, San Diego Region has reviewed the January 2011 monthly monitoring report submitted by the United States Marine Corps in accordance with Monitoring and Reporting Program No. R9-2009-0021.

The following violation of Section B. 4 (Discharge Specifications) of Order No. R9-2009-0021 was identified in the submitted report:

The daily maximum discharge specification for color, established at 15 color units was exceeded on January 12, 2011, with a reported value of 22.5 color units

Please be aware this violation subjects you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;<sup>1</sup> referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report required to be submitted is the February 2011 monthly monitoring report, which is due by March 30, 2011.

<sup>1</sup> Under authority of California Water Code section 13350.

Mr. A.C. Entingh


- 2 -

March 4, 2011

For questions pertaining to the subject matter, please contact Ray Sunjed at (858) 627-3977 or via email at [rsunjed@waterboards.ca.gov](mailto:rsunjed@waterboards.ca.gov).

**PLEASE INCLUDE "638334:RSUNJED" IN THE SUBJECT LINE OF FUTURE CORRESPONDENCE.**

Sincerely,



Brian D. Kelley, PE  
Senior Water Resource Control Engineer  
Cleanup and Land Discharge Branch

Regulatory Measure ID: 377846  
Violation ID: 892945

*California Environmental Protection Agency*

 Recycled Paper